



- NOTES:
- 1.- 90kW @ 480VAC 3 $\phi$  - 109 FLA
  - 2.- 96kW @ 400VAC 3 $\phi$  - 139 FLA
  - 3.- 96kW @ 480VAC 3 $\phi$  - 116 FLA
  - 4.- 108kW @ 480VAC 3 $\phi$  - 131 FLA
  - 5.- 120kW @ 400VAC 3 $\phi$  - 174 FLA
  - 6.- 120kW @ 480VAC 3 $\phi$  - 145 FLA
  - 7.- 144kW @ 400VAC 3 $\phi$  - 209 FLA
  - 8.- 144kW @ 480VAC 3 $\phi$  - 174 FLA
  - 9.- PLUMBING CONNECTIONS: 2" MNPT

REV	BY	DATE	DESCRIPTION OF CHANGE
1	STA	1/08/04	REMOVED HIDDEN LINES

PCN:	.
CUSTOMER No:	.
MATERIAL:	—
	—

DIMENSIONS ARE IN INCHES  
UNLESS OTHERWISE NOTED:  
TOLERANCES ARE:  
0.00 = ±0.015  
0.000 = ±0.010  
ANGLES = ±1°

3rd ANGLE PROJECTION

INCHES  
(mm)

**PROCESS TECHNOLOGY®**  
**LUFRA®** 7010 LINDSAY DRIVE MENTOR, OHIO  
440-946-9500 FAX 440-974-9561

DRAWN BY: MCC	DATE: 03/18/03	DESIGNER: MCC	DATE: 03/18/03
DESCRIPTION TYTAN, 4-6 COLUMN W/ CIRCUIT BREAKER FACILITIES DWG			
APPROVED BY:		SCALE: 1:9	DRAWING No. 1 OF 1 22-0446-01